

Approval Number 2305527
Test Report: MA7963/F



25th May 2023

Compounds AG
Barzloostrasse 1,
8330 Pfaffiken ZH,
Switzerland,

Water Regulations Approval Scheme Ltd.

Unit 13,

Willow Road,

Pen y Fan Industrial Estate,

Crumlin,

Gwent,

NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

RUBBERS- ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY.

5365

'Sunaflex T 8165'. Black coloured, compression moulded EPDM sheet material. Shore hardness 70. Tested in-radius size 1.0mm. For use with water up to 23°C.

APPROVAL NUMBER: 2305527

Confidential

APPROVAL HOLDER: COMPOUNDS AG

This is a re-approval of 1804527 which is valid between April 2018 and April 2023.

The Scheme reserves the right to review approval.

Approval 2305527 is valid between May 2023 and May 2028

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrassapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes'.

Ian Hughes
WRAS Approvals Manager